





# JEFFERSON COUNTY ENVIRONMENTAL SERVICES

## VILLAGE CREEK WATER RECLAMATION FACILITY



CONSTRUCTED: 20xx | PERMITTED AVERAGE CAPACITY: 60.0 MGD each | PEAK FLOW CAPACITY: 200 MGD  
(Combined 0011 & 0021 Facilities)



1440 Pleasant Hill Road Birmingham, AL.  
35224

Village Creek WRF consists of two partially independent treatment facilities with separate outfalls permitted as 0011 and 0021, and are commonly referred to as plant 001 and plant 002 respectively. Each facility is rate to treat 60MGD. Both facilities have preliminary treatment. The 001 facility has primary clarification unlike the 002 facility. Construction is under way that will soon allow 001 primary effluent to be routed proportionally to the 002 facility's headworks. Each facility uses a conventional activated sludge process followed by secondary clarification then disinfection. Plant 001 uses chlorine disinfection whereas the 002 facility has deep bed sand filters followed by ultraviolet disinfection. All waste sludge is sent to anaerobic digesters ahead of centrifuges for biosolids thickening.

Village Creek is the second largest Water Reclamation Facility in Alabama.

- Grade IV facility
- Permitted flow 001 – 60MGD  
Permitted flow 002 – 60MGD
- Plant is staffed 24 hours per day, 365 days per year
- Personnel: 31 (7 Grade IV, 0 Grade III, 2 Grade II, 1 clerk, 6 maintenance crew, 11 operator I, 3 skilled laborers and 1 laborer III)

### Village Creek Wastewater Treatment Plant Energy and Process Optimization Improvements (ongoing) – Expected Completion 2/2019

- Installing automated septic receiving station
- Installing magmeters on influent of 001 plant
- Automating primary sludge pumping
- Adding primary effluent splitter box to send part of primary effluent to the 002 plant
- Converting to single stage activated sludge aeration on the 001 plant with automated D.O. control
- Optimizing anaerobic digester mixing, heating and gas system
- Incorporating FOG receiving and emulsion system ahead of anaerobic digesters
- Installing new dual fuel boilers to heat anaerobic digesters and FOG system
- Replacing 002 influent pump station pumps
- Installing new SCADA system

**Budget:** (Estimated at \$36, 650,000)



## Project in Planning Stage

Phosphorus removal modifications and construction to meet new ADEM phosphorus removal requirements.

- ADEM is mandating phosphorus compliance which is currently estimated to cost taxpayers @ \$42 million just for capital improvements. Chemicals will be required to maintain phosphorus removal and will further add to our fiscal years' operational budgets
- Aging work force
  - Average age of employees 49 years old
- Aging equipment
  - Majority of equipment between at least 18 years old
- Understaffing
  - Grade IV Certified Operators 89% understaffed
  - Shift Supervisors 71% understaffed
  - Maintenance team 22% understaffed
  - Laborer position 50% understaffed
- More maintenance employees
  - While we're not too bad understaffed based on our current budget, our equipment age is to the point where we're spending 90% or more of our time repairing failed equipment. We don't have enough maintenance employees to maintain equipment in order to keep it from breaking down

**Budget:** (Estimated at \$42,000,000)

## Capital Improvement Project #1

Description and photo (if applicable)


**Budget:** (Actual or estimated)

**Director: David Denard | Deputy Director: Margaret Tanner | Plant Manager: Robby Bennett**



JEFFERSON COUNTY ENVIRONMENTAL SERVICES DEPARTMENT  
 VILLAGE CREEK WASTEWATER TREATMENT PLANT AL0023647

FLOW SCHEMATIC - FIGURE 188-B



- Process, Station & Equipment:**
- Plant 001 Liquid Train  
 Bar Screens = 3, 24" diameter type  
 Grit/Pre-Aeration Basins = 4, 0.265 Mgal ea.  
 Primary Clarifiers = 1, 30' diameter, 0.41 Mgal ea.  
 First Stage Aeration Basins = 3, 1.11 Mgal ea.  
 First Stage RAS Screw Pumps = 2, 20,800 gpm ea, 125 HP ea.  
 First Stage Settling Basins = 3, rectangular, 1.9 Mgal ea.  
 Second Stage Aeration Basins = 4, 1.70 Mgal ea.  
 Second Stage Settling Basins #1-4 = rectangular, 0.79 Mgal ea.  
 Second Stage RAS Centrifuge Pumps = 3, 99 gpm, 15.8 HP ea.  
 Second Stage RAS Screw Pumps = 2, 20,800 gpm ea, 125 HP ea.  
 Chlorine Contact Chamber = 1, 1.11 Mgal
- Solids Train  
 Plant 001 Gravitl Thickening = 3, 70' diameter  
 Plant 002 Gravitl Thickening = 3, 40' diameter  
 Aerobic Digesters = 3, 0.49 Mgal ea.  
 Two-Stage Anaerobic Digestion  
 Primary Anaerobic Digesters = 3, 1.65 Mgal ea.  
 Secondary Anaerobic Digesters = 5, 1.83 Mgal ea.  
 Elutriation Tanks = 2, 15.54 Mgal ea.  
 Thickening Centrifuges = 3, Out of Service  
 Dewatering Centrifuges = 3, 300 HP, 320 gpm ea.  
 Drying Beds = 63, 3.3 Mgal total  
 Sludge Spore = 1, 1.92 diameter, 64,000 c
- Plant 002 Liquid Train  
 Bar Screens = 2, 10' wide, 0.79' diameter type  
 Bar Screens = 2, 4' wide, 0.79' diameter type  
 Influent Pump Station = 12 pumps, 420 MGD total capacity  
 Surge Basin = 20, 90 Mgal total  
 Grit/Pre-Aeration Basins = 4, 0.147 Mgal ea.  
 Grease Reactors = 6, 60,200 gal ea.  
 Aeration Basins = 4, 2.36 Mgal ea.  
 Final Clarifiers = 6, 100' diameter, 1.52 Mgal ea.  
 Surge Basin Overflow Fine Screens = 3, 0.25' diameter type  
 Deep bed sand filter = 2, 16 MGD ea.  
 UV Disinfection = 3 channels, 1.0 bank, 33 MGD ea. channel
- Back-Up Power  
 002 Gen. Bldg. = 8, Caterpillar 3616, 3200 kw ea., Natural Gas  
 002 Gen. Bldg. = 1, Ford 10kw, Natural Gas  
 002 Pump Station = 1, Cummins 1, 60kw, Diesel  
 002 Water Tower = 1, Caterpillar 3406, 240kw, Natural Gas  
 001 Turbine Bldg. = 3, Caterpillar 3616, 1000 kw ea., Natural Gas  
 001 Dewatering Bldg. = 2, Caterpillar 3612, 600 kw ea., Natural or Sewer Gas
- Automatic Effluent Samplers  
 001 - American Signis  
 002 - American Signis 900 MAX
- Flow Meters  
 001 Influent - Echo Arrow Hunter (Doppler)  
 001 Effluent - Fisher Foster (Ultrasonic)  
 002 Influent - Pulsar (Ultrasonic)  
 002 Effluent - ABB/Mintronics (Ultrasonic)

Other information